

Inženjerska komora Crne Gore
Stručno predavanje SKMI

VENTILACIJA I PROTIVPOŽARNA BEZBJEDNOST SAOBRAĆAJNIH TUNELA SA PREGLEDOM OBAVEZUJUĆIH STANDARDA I SMJERNICA

Doc.dr Milan Šekularac, dipl.maš.ing.

Mašinski fakultet

Univerzitet Crne Gore

SADRŽAJ

- 1. Tipologija tunela, izvedbe ventilacionih sistema i požar u tunelu**
- 2. Relevantne smjernice i alati za proračun – pregled**
- 3. Procedura proračuna sistema podužne ventilacije**
- 4. Istraživanja u Crnoj Gori. Aktuelna pitanja u ventilaciji tunela**

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

VRSTA SAOBRAĆAJA

Drumski*

Željeznički

KONTEKST

Gradski (urbani)

Ruralni / Autoput*

SMJER SAOBRAĆAJA

Dvosmjerni saobraćaj*

Jednosmjerni saobraćaj*

TIP VENTILACIONOG SISTEMA

Podužna (“longitudal”) ventilacija “jet” ventilatorima*

Poprečna (“transversal”)

Polupoprečna (“semitransvers.”) - kombinovana

*U FOKUSU PAŽNJE DANAŠNJEG PREDAVANJA



1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



St Helena tunnel, Pacific coast highway, SAD

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



Izvor: MoJet

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU





1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU




1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

Osnovne koncepcije u izvedbi ventilacionog Sistema – shema:




1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

Osnovne koncepcije u izvedbi ventilacionog sistema – shema:



c) polu-poprečna




d) poprečna

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

Osnovne koncepcije u izvedbi ventilacionog sistema* - presjek:

- a) Poprečna (“transverse”);
- b) Polu-poprečna (“semi-transverse”);
- c) Podužna (“longitudinal”) ventilacija;



*Application of Multi Objective Optimization Techniques to Improve the Aerodynamic Performance of a Tunnel Ventilation Jet Fan
Article in ARCHIVE Proceedings of the Institution of Mechanical Engineers Part C Journal of Mechanical Engineering Science, January 2015 DOI:
10.1177/0954406214531566

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU




FIGURE 1 - LONGITUDINAL VENTILATION WITH JET FANS




FIGURE 2 - LONGITUDINAL VENTILATION WITH SACCARDO NOZZLE

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU




FIGURE 3 - SEMI-TRANSVERSE VENTILATION:
DURING NORMAL OPERATING CONDITIONS; FRESH AIR INJECTION




FIGURE 4. SEMI-TRANSVERSE VENTILATION WITH REMOTELY CONTROLLED DAMPERS.

Izvor: PIARC „Road Tunnels: Operational strategies for emergency ventilation“ [Note: In case of fire, only the dampers near to the fire are opened. All others are closed.]

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU




FIGURE 5 - TRANSVERSE VENTILATION SYSTEM WITH UNIFORM SUPPLY AND EXTRACT OF AIR.




FIGURE 6 - TRANSVERSE VENTILATION WITH REMOTELY CONTROLLED DAMPERS.

[Note: In case of fire, only the dampers near to the fire are opened. All others are closed.]

Izvor: PIARC „Road Tunnels: Operational strategies for emergency ventilation”

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU





FIGURE 7 - MASSIVE POINT EXTRACTION SYSTEM



1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

Građevinske koncepcije i evakuacija



1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU

Nove građevinske koncepcije



1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



Gothard tunel (SUI)

https://en.wikipedia.org/wiki/Gotthard_Road_Tunnel

<https://www.rts.ch/info/suisse/3540380-incendie-du-gothard-cetait-il-y-a-dix-ans.html>

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



*Kamion koji je prenosio razređivač izaziva udes i požar u tunelu, koji zahvata 11 vozila
Povrijeđenih osoba 21. Mjesto Sangju tunel, Central Inland Expressway, grad Changwon (KOR)*

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



The 5th of May 2017 - five kilometres inside the Oslofjord tunnel.



Kamion u plamenu, vozač izbjegao katastrofu

<https://www.youtube.com/watch?v=rpnCB2OwgVY>

Kamion se samozapalio na autputu Lanhai jugoistočna kineska provincija Guizhou. Prisiljen da brzo rezonuje šta se može desiti ako požar eskalira unutar tunela i opasnosti po samog vozača i sve drugo oko, vozač odlučuje da rizikuje svoj život i odveze kamion bezbjedno van tunela. Ubrzo nakon čega stižu i vatrogasci.

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



Tunel "Mon Blan"

1. TIPOLOGIJA TUNELA, IZVEDBE VENTILACIONIH SISTEMA I POŽAR U TUNELU



Tunel “Mon Blan” katastrofa

<https://www.youtube.com/watch?v=7maggFQQPzJI>

<https://www.youtube.com/watch?v=tcLaogBvIlA>

<https://www.youtube.com/watch?v=PfKpb1uoFoY>

<https://www.youtube.com/watch?v=E U55ranUPs8>

Edited by Haukur Ingason



Proceedings of the
International Symposium on
Catastrophic Tunnel Fires

20–21 November 2003



SP Swedish National Testing and Research Institute

*Zbornik radova sa skupa:
Proceedings of the International Symposium
on Catastrophic Tunnel Fires*

<http://www.diva-portal.org/smash/get/diva2:962271/FULLTEXT01.pdf>

2. Relevantne smjernice i alati za proračun

Smjernice


- ✓ **Austrijski standard (RVS)**
- ✓ **Njemački standard (RABT)**
- ✓ **PIARC (World Road Association, 1909)**
- ✓ **Francuski, švajcarski, i dr.**

Alati za proračun:


- ✓ **Bazični projektni proračun – smjernice i opšta inž. literatura**
- ✓ **Napredni proračun - numerički proračun / simulacija rada sistema / požara**

PIARC TECHNICAL REPORTS

- *PIARC TECHNICAL REPORT 3.05.11.B – 2001 (Geometrija tunela, gustina i protok saobraćaja)*
- *PIARC Committee on Road Tunnels Operation (C3.3) – 2007: SYSTEMS AND EQUIPMENT FOR FIRE AND SMOKE CONTROL IN ROAD TUNNELS*
- ***PIARC Committee on Road Tunnels Operation (C3.3): OPERATIONAL STRATEGIES FOR EMERGENCY VENTILATION, 2011R02***



OBJECTIVES FOR VENTILATION CONTROL	33
OPERATION MODES	33
NORMAL OPERATION	33
EMERGENCY OPERATION.....	35
<i>General aspects</i>	35
<i>Phases</i>	37
<i>Influence of Ventilation on Smoke Distribution and Stratification</i>	41
<i>Influence of Traffic on Ventilation Strategy</i>	43
<i>Smoke-management strategies for the self-rescue phase</i>	43
<i>Ventilation during the assisted rescuing and fire-fighting phases</i>	53
RESPONSE OF VENTILATION CONTROL SYSTEMS TO FIRE	53
INTRODUCTION	53
IMPLICATIONS OF NORMAL OPERATION	55
OVERVIEW OF THE CONTROL PROCESS.....	57
<i>Emergency plans</i>	61
<i>Ventilation Response Principle</i>	63
INPUT DATA DEFINING FIRE AND VENTILATION SCENARIO	65
<i>Fire Detection</i>	65
<i>Tunnel Air Flow Velocity (Anemometer)</i>	67
<i>Ventilation Systems Data</i>	69
<i>Traffic Situation</i>	69
<i>Further Data</i>	71
IMPLEMENTATION OF CONTROL PROCEDURE IN THE CASE OF FIRE.....	71
TESTING	75
COMMISSIONING TESTS	75
PERIODIC SYSTEM TESTS.....	77
MODEL BASED SYSTEM TESTS	79



t_0 – startni trenutak vatre

t_1 – detekcija vatre – događaj “b” (CCTV video det; sensor toplote; vizuelna detekcija operatera; i dr)

t_2 – potvrda požara – događaj “c” (može se poklapati sa t_1 ako postoje sistemi aut.det. Uključuje se požarni alarm i započinju protokoli vanrednog stanja)

t_3 – radni parametri ventilacije postignuti (kašnjenje zbog vremena zaleta sistema)

t_4 – dolazak ekipa za spašavanje – događaj “d”

t_5 – spašavanje uz podršku je započelo

t_6 – početak vatrogasne aktivnosti od ekipe za spašavanje

t_7 – kraj evakuacije

t_8 – kraj vanrednih procedura

Time/Vrijeme



Izvod iz predmetne smjernice PIARC:

„Uticaj ventilacije na distribuciju dima i stratifikaciju

Vreli dim požara u tunelu se diže usled sila prirodnog uzgona. Ako se vazduh ne kreće, ili se kreće vrlo sporo, dim će se širiti ispod plafona na obje strane u odnosu na mjesto požara. Ako je tunel sa nagibom, sile uzgona (efekta dimnjaka) mogu biti dovoljne da pokreću vazduh odn. dim u smjeru uspona. Ispod ovih slojeva dima, sveži vazduh biva uvučen, stvarajući hladnu struju vazduha koja se kreće ka požaru, tj. u suprotnom smjeru u odnosu na dim koji se širi ispod plafona. Ovo raslojavanje između vrućeg gornjeg sloja i hladnijeg donjeg sloja se zove stratifikacija.

Usled složenog procesa razmjene toplote i mase, dim se postepeno hladi i miješa sa vazduhom, te nakon određenog vremena obje (uzvodna i nizvodna) sekcija tunela mogu biti potpuno ispunjene dimom. Dakle, stratifikacija je privremeni fenomen, a iskustvo kaže da ne traje duže od 15min, osim ako se ne održava pogodnim sistemom ventilacije, uključujući i ekstrakciju dima sa plafona i kontrolom podužnog strujanja vazduha. Ovaj period vremena je ključan za korisnike tunela da se samoevakuišu. Dakle, ako je stratifikacija dio strategije za vanrednu situaciju u tunelu, tada pouzdana i robusna kontrola podužnog kretanja vazduha je ključna. Ako je podužna brzina mala, a turbulencija nije izražena, tada se stratifikacija može održati i duže vremena,

*PIARC TECHNICAL COMMITTEE C4 ROAD TUNNEL OPERATIONS
TECHNICAL REPORT:*


***ROAD TUNNELS: VEHICLE EMISSIONS AND AIR DEMAND FOR
VENTILATION***

The World Road Association (PIARC) is a nonprofit organisation established in 1909 to improve international co-operation and to foster progress in the field of roads and road transport. The study that is the subject of this report was defined in the PIARC Strategic Plan 2008 – 2011 approved by the Council of the World Road Association, whose members are representatives of the member national governments. The members of the Technical Committee responsible for this report were nominated by the member national governments for their special competences.

Any opinions, findings, conclusions and recommendations expressed in this publication are those of the authors and do not necessarily reflect the views of their parent organizations or agencies.

This report is available from the internet site of the World Road Association (PIARC) <http://www.piarc.org>

*Copyright by the World Road Association. All rights reserved.
World Road Association (PIARC) La Grande Arche, Paroi nord, Niveau 2
92055 La Défense cedex, FRANCE International Standard Book Number 2-
84060-269-5*



SUMMARY.....	6
INTRODUCTION.....	7
1. TUNNEL AND TRAFFIC DATA.....	8
2. ADMISSIBLE IN-TUNNEL CONCENTRATIONS OF TOXIC GASES	10
2.1. INTRODUCTION	10
2.2. CARBON MONOXIDE CO	11
2.3. NITROGEN OXIDES NO _x	11
2.4. PARTICULATE MATTER (PM) EMISSIONS AND VISIBILITY.....	12
2.5. DESIGN AND THRESHOLD VALUES FOR VENTILATION SIZING	14
2.6. AMBIENT AIR CONCENTRATION (C _{AMB}).....	16
2.7. MINIMUM AIR EXCHANGE.....	16
3. ÉMISSIONS	17
3.1. GENERAL REMARKS.....	17
3.2. EMISSION STANDARDS.....	17
3.3. FLEET SEGMENTATION	18
3.4. CALCULATION PROCEDURE	19
3.5. EMISSION FACTORS - BASE CASE: TECHNOLOGY STANDARD A.....	23
3.6. EMISSION FACTORS FOR OTHER REGIONS	31
3.7. NON EXHAUST PARTICULATE EMISSION FACTORS	33
4. CONCLUSIONS	34
5. BIBLIOGRAPHY / REFERENCES	35
GLOSSARY.....	36

APPENDICES	37
1. LIST OF SYMBOLS.....	37
2. EMISSION FACTORS FOR SPECIFIC COUNTRIES.....	38
2.1. EMISSION FACTORS FOR AUSTRALIA.....	38
2.2. EMISSION FACTORS FOR ALGERIA.....	46
2.3. EMISSION FACTORS FOR CHINA.....	54
3. EMISSION TABLES FOR EURO STANDARDS AND ADDITIONAL INFORMATION	63
3.1. PC GASOLINE NO _x	63
3.2. PC GASOLINE CO.....	65
3.3. PC DIESEL CO	67
3.4. PC DIESEL NO _x	69
3.5. PC DIESEL PM	71
3.6. LDV GASOLINE CO.....	73
3.7. LDV GASOLINE NO _x	75
3.8. LDV DIESEL CO	77
3.9. LDV DIESEL NO _x	79
3.10. LDV DIESEL PM.....	81
3.11. HGV DIESEL CO.....	83
3.12. HGV DIESEL NO _x	85
3.13. HGV DIESEL PM	87
3.14. INFLUENCE DU DÉMARRAGE À FROID	88

2.2 CARBON MONOXIDE CO

For the maximum design conditions, *table 3* gives CO design values for various traffic situations. The 100 ppm value corresponds to the WHO recommendation for short term-exposures [3]. To avoid excessive air demands for rarely occurring congestion conditions, a higher CO-concentration can be allowed.

2.3 NITROGEN OXIDES NO_x

Nitrogen oxide (NO) and nitrogen dioxide (NO₂) are pollutants resulting from the combustion of fossil fuels. Most of the emitted nitrogen oxides (NO_x) consist of NO, which is oxidised into NO₂ in the presence of oxygen (especially ozone, O₃). NO by itself is not considered a harmful pollutant at commonly encountered levels. On the other hand, NO₂ is noxious and can irritate the lungs and lower the resistance to respiratory infections such as influenza.

While in previous years NO_x from combustion processes contained mostly NO (90 to 95% of the NO_x), the implementation of diesel vehicle exhaust gas after-treatment systems (oxygenation catalyst, DPF¹, SCR² systems) tend to significantly increase the primary emitted NO₂ percentages [17].

In many European road tunnels, NO₂ can be around 20 to 30% of NO_x concentrations, which strongly depends on the share of diesel vehicles with exhaust gas after-treatment systems in the vehicle fleet and on the residence time of the NO_x in the tunnel air. Only in tunnels with very few passenger cars with diesel engines will the NO₂ contribution remain below 10%.

2.4.1. Visibility and light extinction

The presence of particulates leads to reduced visibility inside the tunnel. The consideration of visibility criteria in the design of the tunnel ventilation system is required due to the need for visibility levels that exceed the minimum vehicle stopping distance at the design speed. There are two primary sources of PM in a tunnel, exhaust emissions and non-exhaust emissions. Exhaust emissions consist of PM emanating from the tailpipe as a result of fuel combustion. Non-exhaust PM consists of tyre and brake wear, road surface abrasion and re-suspended dust.

Visibility is reduced by the scattering and absorption of light by PM suspended in the air. The amount of light scattering or absorption is highly dependent upon the material, diameter of the particle and particle density. The principle for measuring visibility in a tunnel is based on the fact that a light beam decays in intensity as it passes through air. The level of decay can be used to determine the opacity of air. Opacity meters for tunnels typically use these effects to measure visibility within the tunnel. This process is described by the formula:

$$\text{Equation 2: } E = E_0 \cdot e^{-KL}$$

Where “E₀” is the light source (or emitter) intensity, “E” is the light receptor intensity and “L” is the distance between the emitter and receptor expressed in meter. “K” is the extinction coefficient and is expressed in 1/m.

In tunnel ventilation, it has become customary to express visibility by the extinction coefficient K. Extinction is defined as the loss of intensity E - E₀ after travelling the distance L through the tunnel air relative to the source strength E₀. According to Equation 3, the extinction coefficient is expressed as:

$$\text{Equation 3: } K = -1/L \cdot \ln(E/E_0)$$

Alternatively, visibility can also be represented by transmission “S”. Transmission is the percentage of beam intensity “E” that is lost relative to the source strength E₀ after travelling the distance “L”. It is defined on the basis of Equation 4:

$$\text{Equation 4: } S (\%) = 100 \cdot e^{-KL}$$

The extinction coefficients used for the design of the ventilation system are given below:

- $K = 0.003 \text{ m}^{-1}$ means clear tunnel air (visibility of several hundred meters)
- $K = 0.007 \text{ m}^{-1}$ approximates a haziness of the tunnel air and
- $K = 0.009 \text{ m}^{-1}$ approximates a foggy atmosphere.
- $K = 0.012 \text{ m}^{-1}$, threshold value which should not be exceeded during operation and which results in a very uncomfortable tunnel atmosphere. However, there is normally enough visibility for a vehicle to stop safely at an obstacle.

Strong fluctuations in visibility can occur e.g. when several diesel-trucks move as a group, when some unusually smoky vehicles are in the tunnel, or when the ventilation control reacts too slowly to emission peaks.

**TABLE 3 - DESIGN AND THRESHOLD VALUES FOR CO AND VISIBILITY/
EXTINCTION**

Traffic situation	CO	Visibility	
		Extinction coefficient K	Transmission s (beam length: 100 m)
	ppm	10^{-3} m^{-1}	%
Free flowing peak traffic 50 – 100 km/h	70	5	60
Daily congested traffic, stopped on all lanes	70	7	50
Exceptional congested traffic, stopped on all lanes	100	9	40
Planned maintenance work in a tunnel under traffic*	20	3	75
Threshold values for closing the tunnel**	200	12	30
* National workplace guidelines have to be considered			
** The values given here are for tunnel operation only and not for determining ventilation capacities.			

Some countries impose 50 ppm for CO and a K value of 0.005 m^{-1} as design values for peak flow as well as for daily congested traffic. Widely used values for tunnel design are 70 to 100 ppm for CO and 0.007 m^{-1} for K.

2.7. MINIMUM AIR EXCHANGE

In tunnels with mechanical ventilation, the minimum air exchange rate is determined using design values. Where traffic volumes are low, the minimum fresh air requirement might be quite small. However, the ventilation system should be able to accommodate sudden demands such as for high emitting HGVs.

For such cases, an air-exchange rate of at least 4 times per hour should be considered. Where longitudinal ventilation systems are provided, a minimum longitudinal air velocity of 1.0 to 1.5 m/s is recommended to be used as a design criterion.

TABLE 4 - EC EURO STANDARDS, EMISSIONS FOR PASSENGER CARS, GASOLINE

	Year of implementation	CO	HC	NO _x	HC+NO _x	Particles
		[g/km]				
ECE R 15/03	1979	21.5	1.8	2.5		smoke number
ECE R15/04	1982	16.5			5.1	smoke number
US 83*	1987	2.1	0.25	0.62	0.373	
PC Euro 1	1992	2.72			0.97	0.14
PC gasoline EURO 2	1997	2.2			0.5	
PC gasoline EURO 3	2000	2.3	0.2	0.15		
PC gasoline EURO 4	2005	1.0	0.1	0.08		
PC gasoline EURO 5	2008	1.0	0.100	0.060	0.068 (HCNM**)	0.005 (DI***)
PC gasoline EURO 6	2014	1.0	0.100	0.060	0.068 (HCNM**)	0.005 (DI***)

* Austria, Switzerland, Sweden,

** Non-Methane Hydro Carbons,

*** Direct Injection

For the opacity due to diesel smoke and non-exhaust PM, $(C_{adm} - C_{amb})$ is replaced by K_{adm} .

\dot{V}	Air volume flow [m ³ /h]
n_{veh}	Number of vehicles in tunnel [-]
Q	Emission for CO, NO _x [g/(h.veh)] and emissions of particle matter [m ² /(h.veh)]
C_{adm}	Admissible concentration of pollutant [g/m ³]
C_{amb}	ambient (background) concentration of pollutant [g/m ³]
K_{adm}	admissible extinction coefficient [m ⁻¹]

For example, in the case of CO, the required air volume flow for its dilution is determined by:

$$\dot{V}_{CO} = \sum (n_{pc} \cdot Q_{CO}^{pc} + n_{LDV} \cdot Q_{CO}^{LDV} + n_{HGV} \cdot Q_{CO}^{HGV}) \cdot \frac{1}{C_{CO,adm} - C_{CO,amb}}$$

Ou :

\dot{V}_{CO}	Air volume flow [m ³ /h] necessary for CO dilution
$n_{PC, LDV, HGV}$	Number of vehicles for each type in tunnel [-]
Q_{CO}^{PC}	Passenger car emission for CO [g/(h.veh)]
Q_{CO}^{LDV}	Light-duty vehicle emission for CO [g/(h.veh)]
Q_{CO}^{HGV}	Heavy-goods vehicle emission for CO [g/(h.veh)]
$C_{CO,adm}$	Admissible concentration of CO [g/m ³]
$C_{CO,amb}$	Ambient concentration of CO [g/m ³]

**Njemački standard
RABT (2006)**

ROAD AND TRANSPORTATION RESEARCH ASSOCIATION
WORKING GROUP TRAFFIC ROUTING AND ROAD SAFETY

**Regulations
for the
equipment and operation
of road tunnels**

RABT

*provided by Dambach-Werke GmbH,
Siemens AG, Weiss-Electronic GmbH*

Edition 2006

Reproduced with permission of the Road and Transportation Research Association publishing company (FGSV-Verlag). Authoritative for the application of the Road and Transportation Research Association regulations shall be the version with the latest date of issue, which is available at the Road and Transportation Research Association publishing company: FGSV-Verlag, Wesselinger Straße 17, 50999 Köln (Germany).

4. VENTILATION	20
4.1 REQUIREMENTS	20
4.2 DETERMINATION OF THE FRESH AIR NEED DURING STANDARD OPERATION	20
4.2.1 Criteria.....	20
4.2.2 Determining pollutants from exhaust fumes and tyre abrasion.....	20
4.2.3 Determining traffic conditions.....	21
4.2.4 Nominal values of the CO concentration and visibility reduction.....	21
4.2.5 Amount of fresh air and adjustability of the ventilation.....	21
4.3 FIRE IN THE TUNNEL	22
4.3.1 Requirements.....	22
4.3.2 Determining fire dimension.....	22
4.3.3 Ventilation concepts in the event of fire.....	22
4.3.4 Dimensioning of the ventilation for the event of fire.....	23
4.3.5 Temperature stability of the ventilation system.....	24
4.4 IMMISSIONS DUE TO TUNNEL EXHAUST AIR	24
4.4.1 Requirements.....	24
4.4.2 Immission examinations.....	24
4.4.3 Tunnel ventilation for immission protection.....	25
4.5 VENTILATION SYSTEMS	25
4.5.1 Longitudinal ventilation.....	25
4.5.1.1 Natural ventilation.....	25
4.5.1.2 Mechanical longitudinal ventilation.....	25
4.5.2 Semi-transverse ventilation.....	26
4.5.3 Transverse ventilation.....	26
4.5.4 Combination of the ventilation systems.....	26
4.6 VENTILATION CONTROL	26

provided by Dambach-Werke GmbH,
Stiemens AG, Weiss-Electronic GmbH

9. TRANSPORTATION OF HAZARDOUS GOODS AND COMPARABLE GOODS	51
APPENDIX A: LIGHTING	52
A1. TERMS	52
A2. CALCULATION METHODS.....	54
A2.1 Approximation methods for determining L ₂₀ in case of an unknown composition of the evaluation field....	54
A2.2 Approximation method for determining L ₂₀ if the composition of the 20° evaluation field is unknown.....	54
APPENDIX B: VENTILATION.....	55
B1. BASICS	55
B1.1 Basic values.....	55
B1.2 Calculation parameters of the air quality in road tunnels.....	55
B1.3 Determining road accidents	55
B1.4 Limit speed of the HGVs.....	55
B1.5 Proportion of cars with diesel engine.....	55
B1.6 Mass factor for HGVs	55
B1.7 Consideration of special conditions	56
B2. CARBON MONOXIDE EMISSIONS.....	56
B2.1 Calculation procedure.....	56
B2.2 Influences by speed, inclination and height.....	56
B2.2.1 Influence of speed and inclination.....	56
B2.2.2. Influence of height	57
B2.2.3 Concentrations.....	57
B3. IMPAIRMENT OF VISION	57
B3.1 Definition of the impairment of vision.....	57
B3.2 Calculation method	57
B3.3 Influence due to speed, inclination and height.....	58
B3.3.1 Influence of speed and inclination.....	58
B3.3.2 Influence of heights.....	58
B3.4 Tyre abrasion and resuspension	59

Provided by Dambach-Werke GmbH,
 AG, Weiss-Electronic GmbH





Figure 4: Equipment example vault cross section – depiction of the technical possibilities




Figure 5: Equipment example circular cross section – tubing – depiction of the technical possibilities

Table 9a: Types of ventilation in the event of fire for two-way or one-way traffic with daily stagnant traffic

Tunnel length	Type of ventilation in case of fire
Up to 400 m	Natural longitudinal ventilation
400 to 600 m	Mechanical longitudinal ventilation
600 to 1200 m	After risk analysis: a) Mechanical longitudinal ventilation b) Smoke extraction via a large suction opening c) Smoke extraction via intermediate ceiling with controllable suction openings
From 1200 m	Smoke extraction via intermediate ceiling with controllable suction openings

Table 9b: Types of ventilation in the event of fire for one-way traffic with stagnant traffic as an exception

Tunnel length	Type of ventilation in case of fire
Up to 600 m	Natural ventilation
600 to 3000 m	Mechanical longitudinal ventilation
From 3000 m	Longitudinal ventilation with spot suction ≤ 2000 m or extraction via intermediate ceiling with controllable suction openings

Table 10: Critical longitudinal speed

Gradient	Tunnel cross section	Thermal power		
		30 MW	50 MW	100 MW
0 – 1%	Rectangle	2.3 m/s	2.6 m/s	2.9 m/s
	Vault	2.5 m/s	2.8 m/s	3.1 m/s
2 – 3%	Rectangle	2.5 m/s	2.8 m/s	3.1 m/s
	Vault	2.6 m/s	2.9 m/s	3.3 m/s
3 – 6%	Rectangle	2.7 m/s	3.0 m/s	3.3 m/s
	Vault	2.8 m/s	3.1 m/s	3.6 m/s




Figure 13: Minimum equipment with signal lights – system draft for one-way traffic (can be transferred to two-way traffic correspondingly)




Figure 15: Extended equipment – System draft for one-way traffic (can be transferred to two-way traffic analogously)




Figure 12: Determination of the traffic-related tunnel equipment

4.5 Ventilation systems

4.5.1 Longitudinal ventilation

4.5.1.1 Natural ventilation

Natural ventilation does not require any ventilation-related technical devices. The air exchange occurs by means of the meteorologically-related pressure differences between the portals and the air exchange generated by the vehicles.

4.5.1.2 Mechanical longitudinal ventilation

A longitudinal ventilation results from the generation of an air flow along the tunnel tube due to the overlapping of the piston effect of the vehicles, the meteo-related portal pressure differences, the wind pressure and the effect of ventilators. In standard operation, it is used to dilute the vehicle exhaust fumes; in the event of a fire, it can be used for driving out the smoke.

In standard operation, the speed of the air flow should not exceed 8 m/s for two-way traffic and 10 m/s for one-way traffic. In the event of a fire, the longitudinal ventilation can also be used to influence the speed of the air flow.

Mechanical longitudinal ventilation can be achieved in two ways:

a) Longitudinal ventilation with spot ventilators

The longitudinal flow of the air is generated by means of spot ventilators (Figure 7). This type of ventilation is suitable for short two-way traffic tunnels and for one-way tunnels of any length; however, an additional smoke extraction becomes necessary for the event of a fire from certain tunnel lengths according to Section 4.3.3 (Figure 8).




Figure 7: Longitudinal ventilation with spot ventilators




Figure 8: Longitudinal ventilation and smoke extraction for the event of a fire

One-way traffic tunnels must be divided into ventilation sections through air exchange stations for standard operation depending on the ventilation dimensioning. For these air exchange stations, the following dimensioning rules apply:

- The flow rates in the air exchange stations must be adjusted to the air flow induced in the traffic area by spot ventilators and traffic.
- The exhaust and fresh air openings must be separated from each other. The distance to each other should be ≥ 25 m.
- The cross section area of the exhaust opening must be 30-50% of the traffic area cross section.

The cross section area of the fresh air opening must be larger than the exhaust air opening so that the inflow speed remains < 10 m/s.

The longitudinal ventilation is regulated by changing the number of ventilators in operation.

B2. Carbon monoxide emissions

B2.1 Calculation procedure

The amount of fresh air required per lane for meeting the permitted CO concentration in the tunnel is calculated by means of the following formula:

$$Q_{ZL} = \frac{N \cdot 10^6}{3600 \cdot CO_{perm}} \cdot [E_{CO}(\text{car, petrol}) + E_{CO}(\text{car, diesel}) + E_{CO}(\text{HGV})] \quad (10)$$

When calculating the CO emissions (ECO), differentiations are made between cars with petrol or diesel engines and HGVs. The calculation formula for a lane is as follows:

$$E_{CO}(\text{car, petrol}) = \left(1 - \frac{x_{HGV}}{100}\right) \cdot \left(1 - \frac{x_D}{100}\right) \cdot (q_{CO} \cdot f_{iv} \cdot f_H)_B \quad (11)$$

$$E_{CO}(\text{car, petrol}) = \left(1 - \frac{x_{HGV}}{100}\right) \cdot \left(1 - \frac{x_D}{100}\right) \cdot (q_{CO} \cdot f_{iv} \cdot f_H)_D \quad (12)$$

$$E_{CO}(\text{HGV}) = \left(1 - \frac{x_{HGV}}{100}\right) \cdot (q_{CO} \cdot f_{iv} \cdot f_H \cdot f_M)_{HGV} \quad (13)$$

while the following applies:

- Q_{ZL} = required amount of additional fresh air per lane and kilometre [m^3/s , km, lane]
 N = traffic density of the vehicles per kilometre and lane [veh/km, lane]
 $N = M/v_f$ at flowing traffic with
 M = traffic volume [veh/h, lane]
 v_f = average driving speed on lane [km/h]
 CO_{perm} = permitted CO concentration in ppm according to table 7
 x_{HGV} = proportion of HGVs [%]
 x_D = proportion of cars with diesel engine of the cars in the relating year [%]
 q_{CO} = basic value of CO emission [m^3/h , veh]
 f_{iv} = incline and speed factor [-]
 f_H = height factor [-]
 f_M = mass factor [-]

B2.2 Influences by speed, inclination and height

The required motor power and the working point in the motor characteristics change at other driving conditions compared with the basic value condition. These influences differ according to vehicle and must be determined as average values.

B2.2.1 Influence of speed and inclination

Tables 19 to 21 show the influences with respect to the basic value for the driving conditions standstill (idling), stagnant driving with different average speeds and fast driving. Intermediate values must be interpolated linearly.

RVS - Austrija

1. RVS 09.262 (1997): Uređaji za provjetravanje. Proračun potrebne količine vazduha
2. RVS 09.261 (2001): Smjernice za projektovanje, uređaji za provjetravanje (regularni režim rada tunela)
3. RVS 09.281 (2002): Smjernice za radne i sigurnosne uređaje; Građevinski dio.
4. RVS 09.282 (2005): Oprema za tunele
- 5. RVS 09.02.31 (2008; 2014): Tuneli, oprema, ventilacija, osnovni principi**
6. RVS 09.02.31 (2009): Izgradnja i projektovanje tunela, građevinski aspekti
- 7. RVS 09.02.32 (2019): Tunel, ventilacioni sistem, protok svježeg vazduha**
- 8. RVS 09.02.22 (2014): Tunel, tunnelska oprema, rad i bezbjednost**

RVS 09.02.32 (2019): Tunnel, ventilacioni sistem, protok svježeg vazduha

Tunnel
Tunnelausrüstung
Belüftung

Seite 1

LUFTBEDARFSRECHNUNG

RVS 09.02.32

Entwurf

Tunnel
Ventilation Systems
Fresh Air Demand

Inhaltsverzeichnis

1.	ANWENDUNGSBEREICH	3
2.	ABKÜRZUNGEN	3
3.	RECHENGANG	5
3.1	Berechnung der Verkehrswerte	5
3.1.1	Anzahl der Kraftfahrzeuge	5
3.1.2	Verkehrszusammensetzung	7
3.1.3	Grenzgeschwindigkeit	8
3.2	Berechnung der Emissionen	8
3.2.1	Planungsgrenzwerte	8
3.2.2	Emissionen PKW	9
3.2.3	Emissionen LNF	9
3.2.4	Emissionen LKW	9
4.	BERECHNUNG DES LUFTBEDARFS	10
4.1	Luftbedarf CO pro Fahrstreifen	10
4.2	Luftbedarf Trübe pro Fahrstreifen	10
4.3	Luftbedarf NO_x pro Fahrstreifen	10
4.4	Spezifischer Luftbedarf	10
4.5	Gesamtluftbedarf	11

4.6	Spezifischer Gesamtluftbedarf	11
5.	EMISSIONSFAKTOREN UND EINFLUSSPARAMETER	11
5.1	PKW	11
5.1.1	Kohlenmonoxid-Emissionen	11
5.1.2	Trübe-Emissionen	13
5.1.3	Stickstoffoxid-Emissionen	14
5.1.4	Seehöheneinfluss	15
5.2	LNF	15
5.2.1	Kohlenmonoxid-Emissionen	15
5.2.2	Trübe-Emissionen	16
5.2.3	Stickstoffoxid-Emissionen	17
5.2.4	Seehöheneinfluss	18
5.3	LKW	18
5.3.1	Kohlenmonoxid-Emissionen	19
5.3.2	Trübe-Emissionen	19
5.3.3	Stickstoffoxid-Emissionen	20
5.3.4	Seehöheneinfluss	20

AG:Tunnelbau
AA: T05 Belüftung und Löschsysteme
Details können der Homepage der FSV www.fsv.at entnommen werden,

ÖSTERREICHISCHE
FORSCHUNGSGESELLSCHAFT
STRASSE • SCHIENE • VERKEHR



Wir finden neue Wege.

Dieses Werk ist urheberrechtlich geschützt. Alle Rechte insbesondere die der Übersetzung, des Nachdruckes, der Entnahme von Abbildungen, der Funk-sendung, der Wiedergabe auf fotomechanischem oder ähnlichem Wege und der Speicherung in Datenverarbeitungsanlagen, sind, auch bei nur auszugs-weißer Verwertung, nur der FSV vorbehalten. Bei Erwerb in elektronischer Form ist die Speicherung auf Datenträger im Sinne der Lizenzvereinbarung erlaubt.

**Tunnel
Tunnelausrüstung
Belüftung**

Seite 2

LUFTBEDARFSRECHNUNG

RVS 09.02.32

Entwurf

*Tunnel
Ventilation Systems
Fresh Air Demand*

5.4	Partikelemissionen (Trübe) aus Abrieb und Aufwirbelung	20
6.	ANGEFÜHRTE RICHTLINIEN UND LITERATUR	22

RVS 09.02.31 (2008; 2014): Tuneli, oprema, ventilacija, osnovni principi

Tunnel
Tunnelausrüstung
Belüftung

GRUNDLAGEN

RVS 09.02.31

*Tunnels
Tunnel equipment
Ventilation
Basic principles*

TABLE OF CONTENTS

0	Preliminary remarks.....	2
1	Area of application.....	3
2	Basic principles of planning	3
3	Determining the air requirement	3
3.1	Traffic data	3
3.1.1	Traffic flow	3
3.1.2	Traffic composition	3
3.1.3	Condition of the traffic	4
3.2	Design limit values	4
3.2.1	CO concentration	4
3.2.2	NOx [oxides of nitrogen] concentration.....	4
3.2.3	Turbidity.....	4
3.2.4	Maximum longitudinal speed	4
4	Choice of system	4
4.1	Decision-making criteria	4
4.1.1	Criterion of traffic type/structural conditions	5
4.1.2	Criterion of the situation in the surroundings.....	6
4.1.3	Reviewing the choice of ventilation system.....	6
4.2	Ventilation systems	6
4.2.1	Longitudinal ventilation	7
4.2.2	Semi-transversal ventilation.....	7
4.2.3	Transverse ventilation.....	7

5	Technical specifications	8
5.1	General.....	8
5.2	Fans and ventilators.....	8
5.2.1	Jet fans.....	8
5.2.2	Air intake ventilators and exhaust fans.....	8
5.3	Manoeuvrable smoke dampers.....	9
5.3.1	Operating condition.....	9
5.3.2	Case of fire.....	9
5.3.3	Design parameters.....	9
5.3.4	Specifications.....	10
5.3.5	Operation.....	10
5.3.6	Testing smoke dampers.....	11
5.3.7	Checks, servicing and tests following commissioning.....	12
5.4	Auxiliary equipment.....	12
5.5	Air ducts and structure.....	13
6	Aerodynamic dimensioning.....	13
6.1	General.....	13
6.2	Longitudinal ventilation.....	15
6.3	Semi-transversal and transverse ventilation.....	15
7	Controlling and operating the ventilation system.....	16
7.1	Requirements relating to control.....	16
7.1.1	Measured values and data.....	16
7.1.2	Limit values for barricading the tunnel.....	16
7.1.3	Theoretical values for standard operation.....	16
7.1.4	Limit values for servicing operation.....	16

7.2	Control procedures depending on traffic numbers.....	17
7.2.1	Input values	17
→ 7.2.2	Determining the differential air requirement (q_{diff})	17
7.2.3	Variance analysis of the quantities of air required	18
→ 7.3	Control procedures according to the measured air quality values	19
7.3.1	Description of the control procedure	19
7.3.2	Control parameters.....	20
7.4	Special operation-related requirements	20
7.4.1	Automatic operation.....	20
→ 7.4.1.1	Automatic control during standard operation.....	20
7.4.1.2	Semi-automatic operation	20
→ 7.4.1.3	Automatic control during emergency operation	20
7.4.2	Manual operation	20
7.4.3	Servicing operation	21
7.4.4	Inspection operation	21
7.5	Special system-related requirements	21
→ 7.5.1	Longitudinal ventilation with unidirectional traffic.....	21
→ 7.5.2	Longitudinal ventilation with bi-directional traffic	21
7.5.3	Semi-transversal ventilation.....	22
7.5.4	Transverse ventilation.....	22
7.5.5	Combined ventilation systems	23
7.6	Cross cuts and exits	23
7.7	Portal designs.....	23

8	Smoke and fire behaviour tests	23
8.1	General.....	23
8.2	Fire behaviour tests	23
8.3	Parameter studies using 3D computer programmes	24
9	Simplified risk assessment procedure	24
9.1	Frequency equivalent.....	24
9.2	Equivalent extent of damage S	26
9.2.1	Equivalent extent of damage for unidirectional tunnels	26
9.2.2	Equivalent extent of damage for bi-directional tunnels	27
9.2.3	Coefficients of correction for other influencing factors	28
9.3	Risk equivalent value R and hazard classes	29
9.4	Area of application for the simplified method and notes relating to more in-depth risk analyses	29
9.5	Model principles.....	29
10	Cited Acts, guidelines and standards	30
11	Annex	31
11.1	Application example for unidirectional tunnels.....	31
11.2	Application example for bi-directional tunnels	32

3.2 Design limit values

The quantity of fresh air which is required shall be determined for the traffic condition as per point 3.1.3, as well as in relation to the predicted traffic data, in which connection the limit values given below shall be taken as a basis.

3.2.1 CO concentration

100 ppm shall be accepted as the design limit value for CO concentration.

3.2.2 NO_x [oxides of nitrogen] concentration

If NO_x-controlled tunnel ventilation is required, the design limit value for NO_x, depending on the total amount of immissions introduced in the portal area, shall be stipulated pursuant to RVS 09.02.33.

3.2.3 Turbidity

The extinction coefficient of $7 \cdot 10^{-3} \cdot \text{m}^{-1}$ shall be assumed as the design limit for turbidity.

3.2.4 Maximum longitudinal speed

The longitudinal speed occurring in the tunnel, supported by meteorological influences and the thrust of the vehicle, may not exceed a value of 10 m/s.

4 Choice of system

The key factors when deciding on the ventilation system are cost effectiveness and the safety analysis during operation and in the event of fire. As regards economic considerations, 20 years is anticipated as the service life of electrical machine parts and fittings. As regards the structural works in a tunnel, service life shall generally be set at 80 years.

4.1 Decision-making criteria

The following criteria shall be taken into consideration as regards the operating condition:

- the type of traffic (unidirectional traffic, bi-directional traffic, periodic bi-directional traffic, maximum traffic flow, stop-and-go traffic and suchlike)
- structural conditions (length, gradient, cross section, escape routes and suchlike)
- the situation in the surroundings (immissions, protective measures and suchlike)

4.1.1 Criterion of traffic type/structural conditions

Longitudinal ventilation systems are permitted, depending on the length of the tunnel and the traffic load as per Table 1. With longer tunnels, provision shall be made for transverse ventilation systems or combined systems.

Table 1: Area of application for ventilation systems

Type of traffic	Annual average daily traffic flow/lane [motor vehicles/day]	Tunnel length [m]	Type of ventilation
Unidirectional traffic	-	≤ 500	Natural ventilation
	< 5 000 and low congestion frequency	≤ 700	Natural ventilation
	$\geq 5\ 000$ to < 10 000 and mean congestion frequency	500 to $\leq 3\ 000$	Longitudinal ventilation
	$\geq 5\ 000$ and high congestion frequency	500 to $\leq 1\ 500$	Longitudinal ventilation
	$\geq 5\ 000$ and high congestion frequency	1 500 to $\leq 3\ 000$	Longitudinal ventilation and point exhaust suction (max. gap 750 m)
	-	> 3 000	Exhaust air suction with suspended ceiling

RVS 09.02.31 (2008; 2014): Tuneli, oprema, ventilacija, osnovni principi

Bi-directional traffic	-	≤ 500	Natural ventilation
	$< 2\ 000$	$\leq 700\text{ m}$	Natural ventilation
	$< 5\ 000$ with low congestion frequency	500 to 2 000 m	Longitudinal ventilation
	$< 5\ 000$ and mean congestion frequency	500 to 1 500	Longitudinal ventilation
	$\geq 5\ 000$	1 500 to 3 000	Longitudinal ventilation with point exhaust suction (max. gap 750 m)
	-	$> 3\ 000$	Exhaust air suction with suspended ceiling

Low congestion frequency:

Standard value: ≤ 25 hours/annum

Definition: tunnels and adjoining outdoor road sections are sufficiently efficient; no references to specific causes of congestion

If no external influences on the flow of traffic in the tunnel are indicated (e.g. points of convergence, slip roads with adjoining intersections), generally speaking, a low congestion frequency of 0.29% of the operating time is assumed. This value takes account of tailbacks forming in the area of the tunnel as a result of breakdowns and accidents. If external influences impact on the traffic flow, resulting in jams in the tunnel, a check shall be carried out as to the extent to which congestion frequency is raised as a result.

Mean congestion frequency:

Standard value: 25 to 75 hours/annum

Definition: occasional congestion as a result of intermittent traffic peaks, tunnels and adjoining road sections are sufficiently efficient in the standard scenario and only occasionally overloaded (e.g. as a result of seasonal traffic peaks on individual days during holiday traffic)

High congestion frequency:

Standard value: > 75 hours/annum

Definition: frequent (e.g. daily) congestion as a result of regularly occurring traffic peaks (for instance, owing to the capacity of the tunnel or the adjoining road sections being exceeded on a regular basis, or owing to tailback effects from the secondary network in the case of departure ramps or before crossroads after the tunnel)

The occurrence of a jam with a duration in excess of 20 min/hour is regarded as a congestion hour.

5 Technical specifications

5.1 General

The following technical specifications must be observed by fans and ventilators, their auxiliary equipment and any ventilation ducts:

If provision is made for fans and ventilators, their auxiliary equipment and cabling to operate in flue gas situations (fire scenarios), they must continue to operate at a temperature of 400°C over a two-hour period (e.g. using temperature-controlled forced cooling). The failure of a fan or ventilator should not affect the functionality of other fans or ventilators.

This provision applies, mutatis mutandis, to all components in the exhaust air duct.

As regards jet fans, including cabling in tunnels with longitudinal ventilation and hazard classes I to III, and a minimum distance between the jet fans ≥ 200 m, a temperature stability of 250 °C over a 60-minute period is sufficient.

5.2 Fans and ventilators

5.2.1 Jet fans

The housings of jet fans, including their mountings and sound absorbers, shall be constructed from corrosion-resistant material (at least material quality 1.4571 or higher-value steels in the V5A group). The drive motor and terminal boxes shall be realised with at least degree of protection IP 65 in accordance with the Austrian Electrotechnical Association [German designation: ÖVE].

The jet fan shall be mounted in a way which limits vibrations. The fan or ventilator shall be protected against falling by means of an additional safeguard (e.g. a steel cable).

$$\Delta p_{nat} = (\rho_a \pm \rho_i) \cdot g \cdot L_{Tunnel} \cdot s/100 \text{ [Pa]}$$

$$\Delta p_{Brand} = (\rho_i - \rho_{Brand}) \cdot g \cdot L_{Brand} \cdot s_{Brand} \cdot \eta_{Brand} / 100 \text{ [Pa]}$$

$$\rho = \frac{p}{R_L T} \text{ [kg/m}^3 \text{)}$$

where:

Δp_{nat} is the pressure effect as a result of natural buoyancy [Pa]

Δp_{Brand} is the pressure effect as a result of the heated air (fire) [Pa]

ρ is the density dependent on the temperature and external pressure [kg/m³]

L_{Brand} is the length of the fire compartment [m]

s is the longitudinal gradient [%]

s_{Brand} is the longitudinal gradient in the fire compartment (L_{Brand}) [%]

η_{Brand} is the extent of the effect of the fire (ratio of actual to theoretical heat released)

Index a is outside the tunnel

Index i is inside the tunnel with no fire present

ΔT_{nat} is $T_a - T_i$ [K]

ΔT_{Brand} is $T_i - T_{Brand}$ [K]

In the case of tunnels with a mixture of passenger cars and HGVs, the design fire shall be set at 30 MW. Where the traffic consists solely of passenger cars, this figure shall be 5 MW. As regards tunnels with a higher proportion of HGVs (> 15%), the impact on tunnel safety shall be presented on the basis of a tunnel risk analysis or a risk assessment and an increase in the fire load reviewed as a measure.

The following characteristic values apply to design fires:

		Design fire		
		5 MW	30 MW	50 MW
ΔT_{Brand} without extraction	25 K		65 K	90 K
ΔT_{Brand} with smoke extraction	20 K		40 K	65 K
ΔT_{nat}	10 K		10 K	10 K
L_{Brand}	400 m		800 m	800 m
η_{Brand}	0.85		0.75	0.75

7.1.2 Limit values for barricading the tunnel

The tunnel shall be barricaded automatically if one of the following conditions applies:

- CO levels ≥ 100 ppm for a period exceeding ten minutes
- CO levels ≥ 150 ppm
- an extinction coefficient $\geq 12 \cdot 10^{-3} \cdot \text{m}^{-1}$ for a period exceeding one minute

The tunnel blockade shall be automatically lifted again if

- CO levels of 90 ppm, or
- an extinction coefficient of $7 \cdot 10^{-3} \cdot \text{m}^{-1}$

are fallen short of for a period exceeding one minute and this trend is downwards.

7.1.3 Theoretical values for standard operation

a theoretical CO value of 30 ppm

a theoretical value for turbidity of $4 \cdot 10^{-3} \cdot \text{m}^{-1}$

These values shall be adapted in line with an economic modus operandi during operation.

7.1.4 Limit values for servicing operation

As regards servicing operations which continue over a longer period, the following limit values must be observed in the ventilation section in question:

CO	20 ppm
Turbidity	$3 \cdot 10^{-3} \cdot \text{m}^{-1}$

Provisions concerned with the protection of workers must be heeded.

7.5.1 Longitudinal ventilation with unidirectional traffic

Under standard operation, the envisaged direction of blow of the jet fans is the direction of travel. In a fire situation, the theoretical value for longitudinal speed is 1.5 to 2 m/s. The measurement values specified are valid without measuring tolerances.

For the time being, the jet fans shall be activated starting with the exit portal (suction operation). Depending on the location of the fire, a pressure mode may also be employed. Fumigation of the escape routes must be prevented (fire in the direction of travel after the last escape route). The flow shall be reversed in the adjacent tube and an excess pressure generated in relation to the fire tube by means of suitable ventilation control.

7.5.2 Longitudinal ventilation with bi-directional traffic

Under standard operation, the following criteria must be taken into consideration:

- environmental requirements (control structures, other restrictions),
- the principal direction of the traffic (pronounced),
- pronounced existing natural air flow,
- the preferential direction of the jet fans (efficiency),
- minor changes in the principal direction of traffic flow or in the natural air flow may not result in any change in the direction of discharge of the jet fans.

In a fire situation, the ventilation shall be operated as follows:

- The aim is to achieve an air speed of 1.0 to 1.5 m/s in the tunnel area in order to keep escape routes free from smoke for as long as possible. The measurement values specified are valid without measuring tolerances.
- The existing direction of flow must be maintained.
- A reversal in the direction of flow is permitted if, as a result, the risk for tunnel users can be minimised. Structural conditions and longitudinal speed shall be used as a basis for optimisation.
- Fans and ventilators shall primarily be operated from that side which is located upstream of the fire.

The following criteria must be taken into consideration:

- The location of the source of the fire.
- The number of vehicles, their speed and direction.
- The existing direction of flow at the time fire breaks out.
- The location and principal direction of discharge of the fans and ventilators.

8 Smoke and fire behaviour tests

8.1 General

Fire behaviour tests shall be carried out in tunnel installations with mechanical ventilation. Where mechanical ventilation is not present, the need for these tests shall be reviewed in consultation with the State fire brigade federation.

8.2 Fire behaviour tests

In order to obtain a representative declaration relating to smoke extraction (semi-transversal and transverse ventilation) or to the dispersal of flue gas (longitudinal ventilation), a fire behaviour test is necessary. Prior to clearance for traffic, this test shall be performed in coordination with the competent State fire brigade federation, taking account of local conditions.

The purpose of fire behaviour tests is

- to test the operational efficiency of the safety equipment in case of fire,
- to review the functions of the fire programme and, if necessary, adjust it in line with current knowledge, and
- to familiarise the fire brigade and the operating personnel with the fire situation.

The parameters of the fire behaviour test are as follows:

- two steel cones, each 1 m² in area, 50 to 80 cm high, filled with 20 l of diesel and 5 l of petrol respectively
 - location of the fire cones: adjacent to one another
 - location of the fire: the location of the fire shall be laid down in consultation with the persons responsible for assisting public authorities in planning new ventilation projects.
- The test should be conducted at an unfavourable spot in terms of ventilation.

A record shall be submitted of the result of the fire behaviour test.

Provision shall be made for corresponding barriers to protect the facilities in the environment (carriageway, surfacing).

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

PRORAČUN PADA PRITISKA U TUNELU

Pad pritiska u tunelskoj cijevi predstavlja zbir internog gubitka pritiska (Δp_i) uzrokovanog trenjem i lokalnim gubicima, pada pritiska usled klipnog efekta / otpora vozila odn. saobraćaja (Δp_v) i eksternog gubitka pritiska (Δp_e) usled aerodinamičke interakcije s okolinom.

Interni gubitak pritiska

Strujanje vazduha kroz tunelsku cijev može se opisati kao nestišljivo, jedno-dimenziono, kvazistacionarno strujanje. Stoga se interni gubitak pritiska (Δp_i) određuje na bazi poznatog izraza za pad pritiska u cijevima:

$$\Delta p_i = \underbrace{\left(\lambda_f \cdot \frac{L}{D} \cdot \frac{\rho \cdot v^2}{2} \right)}_{\text{TRENJE}} + \underbrace{\sum_0^L (\zeta) \cdot \frac{\rho \cdot v^2}{2}}_{\text{LOKALNI GUBICI}} \quad [\text{Pa}]$$

gdje su :

λ_f - Darcy-jev koeficijent površinskog trenja [-],

L - dužina tunela [m],

D - hidraulički prečnik tunelske cijevi [m],

ρ - gustina vazduha [kg/m^3],

v - srednja uzdužna brzina vazduha [m/s],

ζ - koeficijent lokalnog otpora

(proširenja/suženja, rasvjeta, signalizacija, ventilatori i sl.) [-].

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Ukoliko se uvede ukupni koeficijent trenja definisan izrazom :

$$\lambda = \lambda_f + \frac{D}{L} \sum_0^L (\zeta)$$

interni gubitak pritiska može se prikazati izrazom koji je po obliku sličan izrazu za proračun pada pritiska usled površinskog trenja:

$$\Delta p_i = \lambda \cdot \frac{L}{D} \cdot \frac{\rho \cdot v^2}{2} \quad [\text{Pa}]$$

Odabrana vrijednost ukupnog koeficijenta trenja iznosi prema podacima iz literature od 0,023 do 0,027. Na bazi podataka iz literature, za presjek i hrapavost tunelske cijevi, brzinu odn Re broj strujanja, srednje mjerodavno λ se često usvaja i veće, reda veličine 0,025 do 0,03.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Pad pritiska uslijed saobraćaja

Kretanje vozila u tunelskoj cijevi izaziva složene aerodinamične efekte koji imaju neposredan uticaj na iznos i distribuciju pritiska u tunelskoj cijevi.

Najznačajnija pojava je tzv. "**efekat klipa**" koji predstavlja indukciju kretanja vazduha u tunelu izazvanu prolazom vozila pri povećanoj brzini vožnje. Pojava spomenutog efekta, koji ustvari predstavlja sumu svih aksijalnih sila koja vozila prilikom vožnje prenose na okolni vazduh, se u uslovima dvosmjernog saobraćaja, približno istog protoka vozila, praktično (približno) poništava odn anulira, dok u tunelu jednosmjernog saobraćaja efekat klipa u regularnom radu može biti dovoljan za provjetravanje tunela odn. obezbijediti brzinu višestruko veću od potrebne za provjetravanje. U režimu požara, zbog zaustavljanja vozila uzvodno od mjesta požara a napuštanja tunela onih vozila koja su to mjesto prošla, efekat klipa odumire od trenutka zastoja do konačnog anuliranja.

U uslovima požarnog incidenta pretpostavlja se da su sva vozila zaustavljena - vozila predstavljaju čisti nepokretni aerodinamični otpor usled smanjenja slobodnog poprečnog presjeka tunela, a određuje se prema izrazu:

$$\Delta p_v = n \cdot \frac{(c_w \cdot A)_{veh}}{A_T} \cdot \frac{1}{2} \cdot \rho \cdot v^2 \quad [\text{Pa}]$$

gdje su :

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Eksterni pad pritiska

Eksterni gubitak pritiska predstavlja kombinaciju djelovanja različitih efekata izvan tunelske cijevi kao što su :

- a) portalni gubici pritiska, tj. pad pritiska ulaza i izlaza vazduha iz tunelske cijevi,
- b) gubici pritiska uslijed konverzije statičkog pritiska u dinamički i obrnuto, neposredno uz portale tunela,
- c) efekat dimnjaka,
- d) otpor samog požara,
- e) uticaj lokalnih vjetrova,
- f) uticaj meteoroloških parametara (barometarske razlike).

a) Portalni gubici pritiska

Definišu se kao lokalni gubici, prema izrazu za lokalni gubitak pritiska na ulazu:

$$\Delta p_{UL} = \zeta_{UL} \cdot \frac{\rho \cdot v^2}{2} \text{ [Pa]}$$

odnosno, kao lokalni gubitak pritiska na izlazu:

$$\Delta p_{IZL} = \zeta_{IZL} \cdot \frac{\rho \cdot v^2}{2} \text{ [Pa]}$$

gdje su koeficijenti lokalnih gubitka:

$$\zeta_{UL} = 0,5 ; \zeta_{IZL} = 1,0$$

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

b) Gubici pritiska usled konverzije pritiska

Gubici pritiska uslijed konverzije statičkog pritiska u dinamički na ulaznom portalu i dinamičkog pritiska u statički na izlaznom portalu, su obzirom na uslove konverzije na oba portala identični, te je njihova razlika jednaka nuli.

c) Efekat dimnjaka

S obzirom da, u principu, zbog nagiba tunela postoji geodetska razlika u položaju portala, javlja se strujanje vazduha u tunelu, u uslovima različitih temperatura unutar i izvan tunelske cijevi. Navedeno strujanje, uslovljeno termostatskim gradijentom pritiska, može biti usmjereno od nižeg prema višem portalu u slučaju da je temperatura vazduha u tunelu viša od temperature okoline (*npr. zbog uticaja vrućih izduvnih gasova i dr*) ili može biti usmjereno od višeg prema nižem portalu u slučaju da je temperatura vazduha u tunelu niža od temperature vanjskog vazduha (*npr. zbog hlađenja vazduha u kontaktu s hladnijim zidovima tunelske cijevi*).

U najjednostavnijoj analizi (RVS 09.02.31 - 2008; literatura), određuje se prema izrazu:

$$\Delta p_t = \rho \cdot g \cdot \frac{\Delta T}{T_t} \cdot \Delta H$$

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

gdje su :

ρ - gustina vazduha na nižem portalu tunela [kg/m^3],

g - gravitaciono ubrzanje 9.81 [m/s^2],

ΔT - razlika srednje ekvivalentne temperature u tunelu i temperature spolj. vazduha na nižem portalu tunela [K],

T_t - srednja temperatura vazduha u tunelu [K],

ΔH - razlika u geodetskoj visini portala [m].

Egzaktno određivanje termostatskog gradijenta pritiska zahtjeva statistički obrađene meteorološke podatke o vremenskoj distribuciji temperatura u tunelskoj cijevi i na oba portala. U nedostatku ovih podataka, uobičajeno se za proračun pretpostavlja da je maksimalna temperaturna razlika $\Delta T = 5-10$ K u slučaju redovnog pogona tunela, što je po pravilu, zanemarivo za rezultate proračuna.

S druge strane u uslovima požarnog incidenta dolazi do strujanja vrućih dimnih gasova prema višim dijelovima tunela, što u određenim uslovima može biti nepovoljan smjer. Zato je potrebno dimenzionisati ventilacioni sistem tako da je u mogućnost da savlada i nadpritisak izazvan efektom dimnjaka usled odn. da pokrene dimne gasove smjeru suprotstavljenom efektu dimnjaka.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Nadpritisak izazvan efektom dimnjaka određuje se prema izrazu (vidi RVS 2008):

$$\Delta p_t = \rho \cdot g \cdot \frac{\Delta T}{T_t} \cdot \eta \cdot \Delta H$$

gdje su :

ρ - gustina vazduha na nižem portalu tunela [kg/m^3],

g - gravitaciono ubrzanje [m/s^2],

ΔT - povećanje srednje temperature u tunelu usled požara [K],

T_t - srednja temperatura vazduha u tunelu [K],

ΔH - razlika u geodetskoj visini relevantna za efekat dimnjaka [m],

η - efekat požara (odnos između stvarnog i teoretskog efekta dimnjaka), iznosi 0,75

Prema istraživanjima obavljenim za potrebe austrijskih smjernica RVS 09.02.31 (2008) na TU Grac (*Technical University of Graz*) za požar od 50 MW povećanje srednje temperature u tunelu na ograničenoj sekciji do max. 800 m iznosi $\Delta T = 90$ K (Tabela 4) a koeficijent $\eta=0.75$.

Tabela 4. Izvod iz RVS 09.02.31: Projektna snaga požara i prosječne temperature dima (tzv ΔT_{Brand}) u tunelskoj cijevi u zavisnosti od mjerodavne dužine tunela (tzv L_{Brand})

	5 MW	30 MW	50 MW
ΔT_{Brand} without smoke extraction	25 K	65 K	90 K
ΔT_{Brand} with smoke extraction	20 K	40 K	65 K
ΔT_{nat}	10 K	10 K	10 K
L_{Brand}	400 m	800 m	800 m
η_{Brand}	0,85	0,75	0,75


3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Check for updates

Advances in
Mechanical
Engineering


Review

Critical review of the common methods to determine the buoyancy-chimney effects in longitudinally-ventilated traffic tunnel fires

Petar V Vukoslavčević¹ and Milan B Šekularac² 

Abstract
Determining the buoyancy-chimney effects (hot smoke stack effects) in the case of a fire in a traffic tunnel with a slope is of key importance in the process of sizing the ventilation system and smoke control. Given the complexity of the unsteady turbulent heated flow of air and combustion products mixture and the transient heat transfer by convection, radiation and tunnel wall conduction, various approximate methods, standards, guidelines, and numerical approaches are used, giving different values for the gas temperature distribution and pressure differences. Depending on the fire heat release rate, tunnel slope, and the length of the fire-affected zone, the differences in pressure can even reach values of over 100%, strongly affecting the ventilation sizing. To evaluate the reliability of available methods, a critical review of various methods is given, and a comparison analysis carried out in the case of a typical unidirectional-traffic tunnel equipped with a longitudinal ventilation system. The temperature field, the pressure rise, and the required number of fan units, required to provide the critical velocity for smoke control, are analyzed.

Keywords
Traffic tunnel, longitudinal ventilation, fire safety, one-dimensional heated flow, buoyancy-chimney effects

Advances in Mechanical Engineering
2022, Vol. 14(5) 1–13
© The Author(s) 2022
DOI: 10.1177/16878132221098859
journals.sagepub.com/home/ade


Analiza problema određivanja raspodjele srednje temperature gasa i efekta dimnjaka može se naći u preglednom radu u prilogu:

<https://doi.org/10.1177/1687813222109885>

<https://journals.sagepub.com/doi/full/10.1177/16878132221098859>

Prezentirani prilaz odn. raspodjelu $T_{avg}(x)$ treba iskoristiti i pri određivanju koeficijenta η_T

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

$$-\dot{m}c_p \frac{1}{P} \frac{dT_{avg}}{dx} = \phi_c + \phi_r,$$

$$\phi_c = h_c(T_{avg} - T_w)(\text{W/m}^2),$$

$$\phi_r = \epsilon F \sigma (T_{avg}^4 - T_w^4)(\text{W/m}^2),$$

$$\Phi_r = h_r(T_{avg} - T_w),$$

$$h_r = \epsilon \sigma (T_{avg} + T_w)(T_{avg}^2 + T_w^2).$$

$$h_{cr} = h_c + h_r,$$

$$h_{crc} = \frac{\phi_c + \phi_r}{T_{avg} - T_\infty},$$


$$-\dot{m}c_p \frac{1}{P} \frac{dT_{avg}}{dx} = h_{cr}(T_{avg} - T_w)$$

$$\Delta p_{ch} = \int_0^L (\rho_a - \rho) g \frac{s}{100} dx = \int_0^L \rho_a \left(1 - \frac{T_a}{T_{avg}(x)}\right) g \frac{s}{100} dx,$$

$$T_{avg}(x, t) = T_\infty + [T_{max} - T_\infty] e^{-\frac{h_{crc, mPx}}{\dot{m}c_p}},$$

$$T_{max} = T_a + \frac{2}{3} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p},$$

$$\Delta p_{ch} = -\frac{\rho_a g s \dot{m}_a c_p}{100 h_{crc, mP}} \ln \frac{\frac{2}{3} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p} e^{-\frac{h_{crc, mP} L}{\dot{m}_a c_p}} + T_a}{T_a + \frac{2}{3} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p}}.$$



Austrian RVS-2014 guidelines

The temperature field and the pressure change according to RVS-2014¹⁰ are to be determined using analogous expressions as equations (8) and (12).

$$T_{avg}(x, t_n) = T_a + \eta_{fire} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p} e^{-\frac{h_{crc,m} P x}{\dot{m}_a c_p}}. \quad (25)$$

$$\Delta p_{ch} = -\frac{\rho_a g s \dot{m}_a c_p}{100 h_{crc,m} P} \ln \frac{\eta_{fire} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p} e^{-\frac{h_{crc,m} P L_{fire}}{\dot{m}_a c_p}} + T_a}{T_a + \eta_{fire} \frac{\dot{Q}(\tau)}{\dot{m}_a c_p}}. \quad (26)$$

The advantage of this approach in comparison to the previous RVS-2008⁹ is the known temperature distribution from the position of the fire to the exit of the tunnel. This enables the calculation of the buoyancy (chimney) effect on pressure change regardless of the tunnel length as well as the influence of the temperature increase to the loss of the jet fans efficiency. The recommended values for the portion of the fire's heat release rate that is convected along the tunnel, η_{fire} , differ from the previously presented ones, as well as the heat transfer coefficient $h_{crc,m}$. The data for η_{fire} and L_{fire} are given in Table 3:

Vukoslavčević and Šekularac

7

Table 3. Characteristic values of the fire affected zone length and the coefficient of the convected part of the fire heat release rate (RVS-2014¹⁰).

Fire heat release rate (MW)	5	30	50
ΔT_{nat} (°K) due to natural convection	10	10	10
L_{fire} (m) with smoke extract	900	900	900
L_{fire} (m) without smoke extract	from fire site to tunnel exit	from fire site to tunnel exit	from fire site to tunnel exit
η_{fire} (-)	0.85	0.75	0.75

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

HRR(t) (Q, “heat release rate” – toplotni kapacitet požara u MW)

Tehnike određivanja: “Oxygen consumption calorimetry method”; Mjerenje gubitka mase materijala koji gori poznatog hemijskog sastava. Tretirano brojnim radovima. Može se naći u priručnicima, radovima i smjernicama. U prilogu je CETU kriva HRR(t):




Figure I. The fire heat release rate with respect to time (CETU’s Guide to road tunnel safety documentation,³⁶ 2003).

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE




Figure 2. Distribution of T_{avg} along the tunnel axis in the case of a fire site 1700 m ahead of tunnel exit in the example tunnel problem.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE




Table 4. Required number of fans obtained by use of different methods for the example tunnel problem.

	RVS-2008 ⁹	RVS-2014 ¹⁰	CETU ⁷	CAMATT ¹²
Number of fans	20	26	24	18

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

d) Otpor mjesta požara

Ventilacioni sistem treba, osim brojnih aerodinamičkih otpora da savlada i otpor prolaska vazduha kroz plameno-dimni stub. Radi se o efektu blokiranja, od strane mjesta požara, pri čemu požar svojim djelovanjem prigušuje vazдушnu struju.

Postoje brojni numerički izrazi i rezultati simulacija koji potvrđuju da otpor požara iznosi od 0 do 35 Pa za široki raspon požarnih snaga do 100 MW. Može se koristiti izraz prema Dutrieue i Jacques (2006. god.) koji glasi:

$$\Delta p_{fire} = \frac{Q^{0.8} \cdot v^{1.5}}{D_H^{1.5}} \cdot C \quad [\text{Pa}]$$

gdje je:

Q – snaga požara, tzv. HRR [W],

v – brzina vazduha [m/s],

D_H – hidraulički prečnik [m], iznosi $D_H = \frac{4A}{O}$, pri čemu je A površina poprečnog presjeka

tunelske cijevi, a O predstavlja obim presjeka tunelske cijevi,

C – empirijska konstanta $41,5 \times 10^{-6}$

Za slučaj tunela tipičnih ulaznih podataka koji slijede:

Q – 50×10^6 W (50 MW)

D_H – 7.5 m

C – $41,5 \times 10^{-6}$

O = 28 m

otpor požara iznosi:

$$\Delta p_{fire} = 14,4 \text{ Pa} , \quad \text{za brzinu } v = 3,0 \text{ m/s}$$

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

e) Uticaj lokalnih vjetrova

Vjetar može imati uticaj na uslove provjetravanja tunela, bilo da pospješuje ili umanjuje efikasnost mehaničke ventilacije. Po pravilu, sistem mehaničke ventilacije treba da se prilagodi rezultatnom strujanju vazduha uspostavljenom u tunelu i na koji svakako ima pozitivan uticaj djelovanje vjetra na portalima tunela. Ovo je naročito evidentno u tunelu dvosmjernog saobraćaja, gdje se klipni efekti od kretanja vozila u suprotnim trakama približno poništavaju.

Međutim, u slučaju požarnog incidenta (ograničena mogućnost pristupa vatrogasnih i spasilačkih ekipa!), sistem ventilacije određuje smjer strujanja prema kriterijumu trenutnih potreba odimljavanja i u tom slučaju dinamički pritisak vjetra može se pojaviti kao dodatni kontrapritisak kojeg mora savladati sistem ventilacije (prema publikaciji PIARC-a "Fire and Smoke Control in Road Tunnels", 1999. god., str. 167. i dr izvori). Potrebno je napomenuti da se uticaj vjetrova ne uzima u obzir s ekstremnim pojavnim vrijednostima, već se za sve vrste vjetrova *uzmaju 95%-tne polusatne srednje vrijednosti brzina, mjerene na 4m iznad tla (prema RVS 09.02.31, Poglavlje 6, Aerodinamičko projektovanje)*. Egzakti meteorološki podaci o vjetrovima često nisu dostupni.

Uvidom u literaturu, meteo podatke i projektnu dokumentaciju za 1. fazu autoputa, u dosadašnjoj praksi je uzimano da na portalu tunela duva vjetar brzine 30 km/h (8,3 m/s), paralelno osi tunela ($\phi_w = 0^\circ$), a koeficijent oblika portala iznosi $c_w = 0,7$. U tom slučaju, na portalu tunela se javlja nadpritisak vjetra (Δp_w), opisan sledećim izrazom:

$$\Delta p_w = c_w \cdot \frac{\rho \cdot w^2}{2} \cdot \cos \phi_w \quad \text{Pa}$$

Za gore opisane uslove iznosi: $\approx 30\text{Pa}$

f) Uticaj meteo razlike pritisaka (barometarski nadpritisak)

Gradijent pritiska koji se može pojaviti zbog razlike barometarskih pritisaka na portalima svedenih na istu visinu, može uticati na formiranje strujanja u tunelu.

Spomenuta razlika pritisaka na portalima pojavljuje se samo kod dužih tunela, koji se nalaze na granici različitih klimatskih zona.

Određivanje ove razlike pritisaka je složeno. Postoje formule dobijene empirijski za alpske uslove. Iskustvo komandnog centra tunela Sozina pokazuje da je prirodna promaja u tunelu nekada (isključena ventilacija, tunel dvosmjernog saobraćaja) reda veličine 1-2m/s ili veća - što govori o značajnim barometarskim razlikama pritisaka između portala!

Ako se tunel nalazi na razmeđu klimatskih zona moguće se razlike pritisaka od reda veličine 100-200Pa i više, što dramatično utiče na dimenzionisanje ventilacije.

Zanemarivanje ovog uticaja može imati dramatične negativne posljedice na bezbjednost tunela u slučaju požara.

Jedini ispravan prilaz su adekvatna meteorološka mjerenja barometarskih pritisaka na pozicijama portala planiranih tunela, prije faze projektovanja ventilacije. Mjerenja se moraju uraditi u trajanju od barem godinu dana, odn. minimalno sezonski (ljetno vs zima) zbog mogućih značajnih razlika.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Određivanje potrebnog broja ventilatora

Određivanje potrebnog broja aksijalnih ventilatora koji svojim impulsnim djelovanjem indukuju kretanje struje vazduha u tunelu vrši se po formuli:

$$n = \frac{N_{UK}}{N_E}$$

gdje su :

N_{UK} - ukupna sila potiska [N],

N_E - efektivna sila potiska jednog ventilatora [N]

Ukupno potrebna sila potiska N_{UK} (engl. "thrust"), koju treba da ostvari sistem ventilacije, određuje se na bazi izraza:

$$N_{UK} = \Delta p_{UK} \cdot A \quad [N]$$

gdje su :

Δp_{UK} -ukupni pritisak koji ventilacioni sistem mora svladati [Pa],

A -poprečni presjek tunelske cijevi [m²].

Potisna sila tipičnog tunelskog ventilatora je obično reda veličine 900-1000 N

Efektivna (iskoristiva) sila potiska pojedinačnog ventilatora u realnim uslovima (regularnog rada) u tunelu, prenesena na struju vazduha po presjeku tunela, je uvijek manja od nominalno deklarisanе staticke sile potiska a određuje se izrazom :

$$N_E = N_S \cdot \left(1 - \frac{u_t}{u_j}\right) \cdot C_1 \cdot C_2 \cdot C_3 = N_S \cdot k \cdot \eta_i \quad [\text{N}]$$

gdje su:

N_S - staticka sila potiska ventilatora prema podacima iz kataloga proizvođača [N],

$k = 1 - u_t / u_j$ – faktor diktiran brzinama (~0.9)

η_i - efikasnost prenosa impulsa ($=C_1C_2C_3 = \sim 0.70-0.85$)

u_t - uzdužna brzina vazduha u tunelu [m/s], određeno izrazom : Q/A

u_j - izlazna (impulsna) brzina mlaza vazduha iz ventilatora [m/s],

C_1 - instalacioni faktor, kao funkcija položaja ventilatora unutar ventilatorske baterije, u principu 1,00.

C_2 - instalacioni faktor, kao funkcija udaljenosti ventilatora od svoda tunela, red veličine ~ 0,75

C_3 - instalacioni faktor, kao funkcija međusobne udaljenosti ventilatora. U principu je ~1 kada je međusobna udaljenost baterija duž tunela, u skladu s preporukom tj. $\geq 100 \times D_v$ (po pravilu ~100m ili više).

3. PROCEDURA PR

Budući da je za dimenzionisanje ventilacije mjerodavan režim požara, ukupnu silu potiska N_E treba pomnožiti i sa koeficijentom iskorišćenja (umanjenja sile potiska) η_T po osnovu povišene temperature gasa u tunelu (niže gustine odn masenog protoka gasa kroz ventilatore), koji se sračunava po formuli (PIARC):

$$\eta_T = \frac{\left(\frac{T_0}{T}u_j - u_0\right)}{u_j - u_0} \quad (*)$$

$$\text{tj. } N_E = N_S \cdot k \cdot \eta_i \cdot \eta_T ,$$

gdje su:

- u_j brzina mlaza na izlazu iz ventilatora ($\approx \text{const}$)
- u_0 brzina vazduha u tunelu (kritična brzina za kontrolu dima, u hladnom dijelu tunela, tj. $u_0 = u_{kr} = \sim 2.8 - 3.5 \text{ m/s} = \text{const}$)
- T lokalna srednja temperatura gasa po poprečnom presjeku tunela, tj $T=T(x)$.

U francuskoj smjernici („Dossier – Pilote“ CETU) može se naći sledeći izraz za η_T :

$$N_E = \eta_i \cdot N_S \cdot \frac{T_0}{T} \left(1 - \frac{u_0}{u_j} \frac{T}{T_0} \right) \quad (**)$$

Može se pokazati da je (*) ekvivalentan izrazu (**).

Kritična brzina za kontrolu dima $u_{cr} = f(Q)$

Control of smoke flow in tunnel fires using longitudinal ventilation systems—A study of the critical velocity. November 2000.

[Fire Safety Journal](#) 35(4):363-390.

DOI: [10.1016/S0379-7112\(00\)00031-X](https://doi.org/10.1016/S0379-7112(00)00031-X)



Fire Safety Journal 35 (2000) 363–390

**FIRE
SAFETY
JOURNAL**

www.elsevier.com/locate/firesaf

Control of smoke flow in tunnel fires using longitudinal ventilation systems – a study of the critical velocity

Y. Wu*, M.Z.A. Bakar

Department of Chemical and Process Engineering, Sheffield University, Mappin Street, Sheffield S1 3JD, UK

Received 16 February 2000; received in revised form 24 May 2000; accepted 31 May 2000

Abstract

The “critical velocity” is the minimum air velocity required to suppress the smoke spreading against the longitudinal ventilation flow during tunnel fire situations. The current techniques for prediction of the values of the critical velocity for various tunnels were mainly based on semi-empirical equations obtained from the Froude number preservation combining with some experimental data. There are a few uncertainties in the current methods of prediction of the critical ventilation velocity. The first is the influence of the fire power on the critical ventilation velocity. The second is the effect of the tunnel geometry on the critical velocity. Both problems lead to the issues of the scaling techniques in tunnel fires. This study addressed these problems by carrying out a series of experimental tests in five model tunnels having the same height but different cross-sectional geometry. Detailed temperature and velocity distributions in the tunnels have been carried out. The experimental results showed that the critical velocity did vary with the tunnel cross-sectional geometry. It was also shown clearly that there are two

3. Experimental rigs

A new series of experimental tests have been carried out using five model tunnels. The schematic side view and cross-section of the tunnels is shown in Fig. 1. The




Fig. 1. Schematic side view and internal cross-section of the model tunnels.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

$$Q'' = \frac{Q}{\rho_0 T_0 C_p g^{1/2} \bar{H}^{5/2}}, \quad V'' = \frac{V}{\sqrt{g \bar{H}}}$$




Fig. 4. The dimensionless critical velocity V'' vs. the dimensionless heat release rate Q'' . The hydraulic tunnel height is used as the characteristic length.

equations are

$$V'' = 0.40[0.20]^{-1/3}[Q'']^{1/3} \quad \text{for } Q'' \leq 0.20, \quad (15)$$

$$V'' = 0.40 \quad \text{for } Q'' > 0.20. \quad (16)$$

In the derivations of the above equations, the variation of V'' against Q'' was divided into two regions. In the first region, V'' was considered to be increasing with the one-third power of the dimensionless heat release rate, Q'' . In the second region, the value of V'' becomes independent of Q'' , and equal to 0.40.


ANALIZA

Numerički primjer

- Ulazni podaci odgovaraju opštem slučaju tunela jednosmjernog saobraćaja – autoput (CG)



Tunnel cross section area A_t [m ²]	Considered tunnel length L_t [m]	D_h Tunnel hydraulic diameter [m]	Inflow air velocity: u_{cr} [m/s]	HRR_{max} [MW]	Effective Darcy friction factor f_D	Tunnel wall thermal properties
55.1	800	7.7	3	50	0.0275	$k=1.65$ W/mK $\rho=2400$ kg/m ³ $c = 920$ J/kgK

- Prilaz u rješavanju: 1D CFD – CAMATT software (CETU)*
- Rješenje izvezeno za vremenski trenutak: $t=15min: T_{avg}(x), T_w(x)$



*CAMATT 2.20, 2011. Centre d'Etudes des Tunnels, France.

Numerički rezultat



SREDNJE VRIJEDNOSTI KOEFICIJENATA PRENOSA TOPLOTE

$$h_{*,m} = \frac{\int_0^L h_*(T_{avg}(x) - T_w(x)) P dx}{\int_0^L (T_{avg}(x) - T_w(x)) P dx}, \quad h_* \text{ is: } h_c(x), h_r(x), \text{ or } h_{cr}(x)$$

$$h_{crc,m} = \frac{\int_0^L h_{crc}(T_{avg}(x) - T_0) P dx}{\int_0^L (T_{avg}(x) - T_0) P dx}$$

SRAČUNATE SREDNJE VRIJEDNOSTI ZA h_c , h_r , h_{cr} , h_{crc}

HRR	$h_{c,m}$	$h_{r,m}$	$h_{cr,m}$	$h_{crc,m}$
50 MW	13.7	7.53	21.33	16.1

KOEFICIJENT TRENJA I KOEF. KONVEKCIJE – LITERATURNE VRIJEDNOSTI

ULAZNI PODACI ZA NUMERIČKI SLUČAJ (OPŠTI TUNEL):

$$Pr=0.7$$

$$T_0=288K$$

$$\nu=2.2986 \cdot 10^{-5} \text{ m}^2/\text{s}$$

$$k = 0.0316 \text{ W/mK}$$

$$T_m=70^\circ\text{C}$$

$$u_m = 3.57 \text{ m/s}$$

$$Re = 1.33 \cdot 10^6$$

Absolutna hrapavost: ~ 3-9mm

⇒ Darcy koeficijent trenja : $f_D = 0.011 \mid 0.016 \mid 0.020$

- Efektivna f_D vrijednost* u tunelima (hrapavi zid) : **0.023 – 0.026, ili više**

- Usvojeno za numerički primjer tunela - opšteg-slučaja: **$f_D = 0.0275$**

*Jang HM and Chen F. On the determination of the aerodynamic coefficients of highway tunnels. *Journal of Wind Engineering and Industrial Aerodynamics* 2002; 90: 869–896.

** Levoni P, Angeli D, Stalio E, et al. Fluid dynamics characterization of the Mont Blanc tunnel by multi-point airflow measurements. *Tunneling and underground space technology* 2015; 48: 110-122.

VRIJEDNOST KOEF. KONVEKCIJE ZA "GLATKU" TUNELSKU CIJEV $f_D=0.011$

General formula: $h_{c,s} = 0.0265 \cdot Re_m^{0.8} \cdot Pr^{0.333} \cdot k_m / D_h = \dots = 7.58 \text{ W/m}^2\text{K}$

Sieder-Tate formula: $h_{c,s} = 0.027 \cdot Re_m^{0.8} \cdot Pr^{0.3} \cdot k_m / D_h \cdot (v_m/v)^{0.14} \dots = 8.11 \text{ W/m}^2\text{K}$

Newman formula: $h_{c,s} = 0.026 \cdot Re_m^{-0.2} \cdot (1 + (D_h/1500)^{0.7}) \cdot 1.2 \cdot 1010 \cdot u_m = 7.48 \text{ W/m}^2\text{K}$

Petukhov: $h_{c,s} = \frac{\frac{f_D}{8} c_p \rho u}{1.07 + 12.7 \left(Pr^{\frac{2}{3}} - 1 \right) \sqrt{\frac{f_D}{8}}} = \dots = 5.03 \text{ W/m}^2\text{K}$

"HRAPAVA" CIJEV TUNELA – VRIJEDNOST KOEF. KONVEKCIJE:

- Petukhov ($f_D = 0.0275$): $\dots h_{c,ro} = 13.7 \text{ W/m}^2\text{K}$


- Norris formula*:

$$h_{c,ro} = h_{c,sm} \left(\frac{f_{D,ro}}{f_{D,sm}} \right)^n, n = 0.68 \cdot Pr^{0.215} \dots h_{c,ro} = 14.45 \mid 8.97 \mid 13.32 \text{ W/m}^2\text{K}$$


Shodno relativnoj hrapavosti odgovarajući opseg f_D : $f_D = (f_{D,smooth} - 4 f_{D,smooth})$

*Kays WM, and Crawford ME. Convective heat and mass transfer. McGraw – Hill, Inc. 1980. McGraw Hill series in mechanical engineering. ISBN 0-07-033457-9.

UTICAJ EFEKTIVNOG DARCY KOEF. TRENJA f_D NA KOEF. KONVEKCIJE h_c



3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE



1 Reducing the Coanda effect

The discharged jet is turned away from the tunnel surfaces, which significantly reduces the proportion of thrust lost due to aerodynamic friction. The MoJet® achieves this by using an inclined trailing edge, and a bellmouth design which improves the flow conditions at the inlet side, while acting as a deflector on the outlet side.

2 Static pressure recovery

downstream of the fan (due to an increase in silencer cross-sectional area). This means that more thrust is generated using the static pressure at the outlet (which is a reversible, efficient process) rather than the discharge velocity (an irreversible, inefficient process).

3 Increased mass flowrate

through the fan (due to reduced inlet and outlet pressure drops). The pressure drops at the inlet and outlet are reduced due to the larger cross-sectional areas compared to conventional jetfans.

4 Confining effects of the tunnel soffit on the silencer inlet are reduced

because the silencer inlet area is directed away from the tunnel soffit.


5 Reduced discharge velocity

leading to lower shear stress at the tunnel soffit immediately downstream of the MoJet®.


Izvor: MoJet (Fathi Tarada):

<https://mojet.global/>

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE



3D CFD Calculations




Confirmation of the additional thrust, on the basis of ANSYS Fluent modelling.

Izvor: <https://mojet.global/>


Izvor:

<https://mojet.global/>


Jet Fan Technologies



Conventional jet fan



Jet fan with deflectors




Slanted silencers



Shaped nozzles

Oldest



Most recent

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Izvor: Road tunnel fire safety and risk: a review
Gehandler Fire Science Reviews (2015) 4:2
DOI 10.1186/s40038-015-0006-6





Figure 1 A schematic diagram over a tunnel fire introducing several important terms.

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE



Struja

- 1 – struja svježeg vazduha
- 1R – vazduh usisan u hem. reakciju sagorijevanja
- 2 – vazduh koji je bajpasirao reakciju (1-1R)
- D – dim (produkti reakcije)
- 3 – konačna smješa po uništenju stratifikacije

C_xH_y

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Za ulazne podatke: $u=3\text{m/s}$, $T_0=15^\circ\text{C}$, $A=55\text{m}^2$; $h_{\text{cfc}}= 18\text{W/m}^2\text{K}$; $M_{\text{gor}} = 48.9 \text{ kg/kmol}$ (TNG 65-35% propan-butan)

Gubitak toplote zračenjem: $Q_r = -1/3 \text{ HRR}$

$T_{\text{max}} = 1350^\circ\text{C}$

⇔ iter. proračunom se dobija: koef. viška vazduha $\lambda = 1.115$ & sledeći sastav / koordinate / protok struja: (1), (1R), (2), (D), (3):

	1	1R	2	D	3	Gorivo
$\dot{n} \text{ [kmol/s]}$	6.973	0.6572	6.316	0.706	7.022	0.0224
$\dot{m} \text{ [kmol/s]}$	202.22	19.06	183.16	20.05	203.2	1.096
$r_{\text{C}_3\text{H}_8} \text{ [/]}$	-	-	-	-	-	0.65
$r_{\text{C}_4\text{H}_{10}} \text{ [/]}$	-	-	-	-	-	0.35
$r_{\text{O}_2} \text{ [/]}$	0.21	0.21	0.21	0.0202	0.1909	-
$r_{\text{N}_2} \text{ [/]}$	0.79	0.79	0.79	0.7354	0.7845	-
$r_{\text{H}_2\text{O}} \text{ [/]}$	-	-	-	0.1381	0.01388	-
$r_{\text{CO}_2} \text{ [/]}$	-	-	-	0.1063	0.01069	-
$\rho \text{ [kg/m}^3\text{]}$	1.225	1.225	1.225	0.213	0.832	tečno
T [K]	288	288	288	1623.15	421.55	300
R	287	287	287	292.73	288.7	-

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

The image shows two overlapping dialog boxes from the ANSYS Fluent software interface. The background is a 3D grid representing a duct or channel.

Species Model Dialog:

- Model:** Species Transport, Non-Premixed Combustion, Premixed Combustion, Partially Premixed Combustion, Composition PDF Transport
- Mixture Properties:** Mixture Material: pdf-mixture (with Edit... button), Import CHEMKIN Mechanism... button, Number of Volumetric Species: 30
- Turbulence-Chemistry Interaction:** Finite-Rate/No TCI, Finite-Rate/Eddy-Dissipation, Eddy-Dissipation, Eddy-Dissipation Concept, Coal Calculator... button
- Reactions:** Volumetric, Wall Surface, Particle Surface, Electrochemical
- Chemistry Solver:** None - Direct Source (dropdown), Select Boundary Species button, Select Reported Residuals button
- Options:** Diffusion Energy Source, Full Multicomponent Diffusion, Thermal Diffusion
- Buttons: OK, Apply, Cancel, Help

Select Boundary Species Dialog:

- Unselected:** Species (Filter Text), icons for list, check, and delete.
- Selected:** Species (Filter Text), icons for list, check, and delete. List of species: n2, o2, c3h8, c4h10, h2o, co2, co, oh, h2, h, o.
- Buttons: Add, Remove, OK, Cancel, Help

At the bottom left, a terminal window shows the following text:

```
Current fuel mass-flow-rate:  
Time = 0.000000 se  
Targeted mass-flow rate set ri  
Current fuel mass-flow-rate:
```

3. PROCEDURA PRORAČUNA SISTEMA PODUŽNE VENTILACIJE

Species Model [X]

Model

- Off
- Species Transport
- Non-Premixed Combustion
- Premixed Combustion
- Partially Premixed Combustion
- Composition PDF Transport

PDF Options

- Inlet Diffusion
- Compressibility Effects
- Liquid Micro-Mixing

Chemistry | **Boundary** | **Control** | **Flamelet** | **Table** | **Premix** | **Properties**

State Relation

- Chemical Equilibrium
- Steady Diffusion Flamelet
- Unsteady Diffusion Flamelet
- Diesel Unsteady Flamelet
- Flamelet Generated Manifold

Energy Treatment

- Adiabatic
- Non-Adiabatic

Model Settings

Operating Pressure [Pa]

Options

- Create Flamelet
- Import Flamelet

File Type

- Standard
- CFX-RIF

Flamelet Property File Name


5. ISTRAŽIVANJA U CRNOJ GORI. AKTUELNA PITANJA U VENTILACIJI TUNELA

Na Mašinskom fakultetu u Podgorici problematika ventilisanja saobraćajnih tunela bila je predmet istraživanja kroz dva nacionalna naučno-istraživačka projekta i jednog bilateralnog sa Mašinskim fakultetom u Beogradu, tokom poslednjih 13 g. Iz ovog istraživanja na MF Podgorica publikovani su sledeći radovi:

1. Vukoslavčević, P., Šekularac, M. (2022) Critical review of the common methods to determine the buoyancy-chimney effects in longitudinally-ventilated traffic tunnel fires. *Advances in Mechanical Engineering*, Vol 14(5) 1-13.
2. Šekularac, M. On heat transfer coefficients and temperature distribution in longitudinally ventilated tunnel fires. 11th International Conference 'Tunnel Safety and Ventilation' 2022, Graz
3. Šekularac, M., Jankovic, N., Vukoslavcevic, P. (2016) Ventilation Performance and Pollutant Flow in a Unidirectional Traffic Road Tunnel. *Thermal Science Journal*, DOI: 10.2298/TSCI160321117S. Year 2017, Vol. 21, Suppl. 3, pp. S783-S794
4. Šekularac, M. (2016) Experimental Determination of Tunnel Ventilation Axial Ducted Fan Performance. *Thermal Science Journal*, DOI.10.2298/TSCI 140624108S ; Year 2016, Vol. 20, No. 1, pp. 209-221
5. Šekularac, M., Janković N. Experimental and numerical analysis of flow field and ventilation performance in a traffic tunnel ventilated by axial fans, *Theoretical and applied mechanics*, DOI: <https://doi.org/10.2298/TAM171201010S> (2018)
6. Šekularac, M. Analiza složenih strujnih polja sistema ventilacije saobraćajnih tunela. Doktorska disertacija, Univerzitet Crne Gore, Mašinski fakultet Podgorica, 2015.
7. Šekularac, M., Vukoslavčević, P. One Approach to Experimental and Numerical Investigation of Longitudinally Ventilated Road Tunnels. (2012) ICTTE International Conference on Traffic and Transport Engineering, Belgrade. Nov.2012. Volume 1; pp. 499-507.; ISBN 978-86-916153-0-7; COBISS.SR-ID 195032076;
8. Šekularac, M, Radulović, P. Energy Efficiency of Ventilation Systems of Longitudinally Ventilated Traffic Tunnels. (2011) International conference on Alternative energy sources and energy efficiency, CANU – Montenegrin Academy of Sciences and Arts. Oct.2011. Scientific meetings Vol.112, Section of Natural Sciences Vol.15, pp.131-147. ISBN 978-86-7215-292-0




a)




b)





c)





d)




a)




b)







a) Intenzitet brzine




b) Radijalna komponenta \bar{v}_r




c) Tangentna komponenta brzine \bar{v}_t






Polje aksijalne komponente brzine u vremenu & strujnice



Polje temperature u zoni požara



Polje temperature u zoni požara: opseg +0 - +60°C

**Hanover, Njemačka
Jan 2023.**







Final results of project BRAFA

Full scale fire tests of Battery Electric Vehicles in Tunnels

Ao.Univ.-Prof. Dipl.-Ing. Dr.techn. **Peter Sturm**

Graz University of Technology, Institute of Internal Combustion Engines and Thermodynamics, Graz, AT, sturm@ivt.tugraz.at

Dipl.-Ing. **Patrik Föbleitner**, BSc


Forschungsgesellschaft für Verbrennungskraftmaschinen und Thermodynamik mbH, Graz, AT, foessleitner@ivt.tugraz.at

Experiments - Vehicles

No	Car type	Drive type	Ignition	Note
BV01	BEV compact car (2020)	ca. 80 kWh, NMC	Starting from battery: triggering a short circuit in the battery by flooding with NaCl _{aq}	Use of fire blanket
BV02	BEV utility vehicle (2016)	24 kWh, LMO	Starting from battery: External heat supply with gas burners	
BV03	ICEV SUV (2020)	Diesel	Starting from interior	
BV04	ICEV utility vehicle (2010)	Diesel	Starting from engine compartment	
BV05	BEV SUV (2020)	ca. 80 kWh, NMC	Starting from interior After 10 minutes: triggering a short circuit in the battery by flooding with NaCl _{aq}	Use of extinguishing nozzle

Note: NMC = nickel manganese cobalt; LMO = lithium ion manganese oxide

Results - Heat Release Rate



Results – Acid gases

№	SO ₂ [mg/Nm ³]			H ₃ PO ₄ [mg/Nm ³]			HCl [mg/Nm ³]			HF [mg/Nm ³]		
	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m
Height	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m	6,4m	4,8m	1,6m
BV01 (BEV)	2,8	14,3	1,5	2,5	1,3	0,3	61,8	31,0	4,4	38,4	10,3	13,5
BV02 (ICE)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
BV03 (BEV)	0,9	3,0	0,5	0,1	0,1	0,1	61,2	32,1	0,9	8,3	3,2	0,7
BV04 (ICE)	n/a	3,7	n/a	n/a	n/a	n/a	n/a	6,3	n/a	n/a	*	n/a
BV05 (BEV)	0,5	9,3	0,7	n/a	n/a	n/a	18,8	35,0	2,6	17,3	20,1	5,3
IDLH-30	286			1092			81			27		

Note: n/a = not analysed, * = value less than detection limit

Conclusions

- Tests performed for
 - Battery cells, modules, packs
 - Vehicles (3 BEV, 2 ICEV)
- Comparison of BEV:
 - **HRR:** average HRR as ICEV, peak HRR higher
 - **Acid gases:** HF increased values
HCl similar to ICEV
- Extinguishing techniques:
 - **Fire blanket:** no successful application
 - **Extinguishing lance:** effective, but difficult to use
 - **Water (standard approach):** currently still the standard recommended method for fire fighting

An aerial photograph of a newly constructed highway cutting through a mountainous landscape. The road features two parallel tunnels with dark asphalt surfaces and white dashed lane markings. The surrounding terrain is rugged, with rocky slopes and sparse green vegetation. In the background, a large, blue-tinted mountain range is visible under a clear sky. A yellow text box is overlaid on the lower portion of the image.

Hvala na pažnji

Kontakt

Doc dr Milan Šekularac, dipl.maš.ing

milans@ucg.ac.me

milan.sekularac.mne@gmail.com

Mašinski fakultet Podgorica

Univerzitet Crne Gore

Cetinjski put bb, 81000 Podgorica